

BRANZ Type Test Summary

This is to certify that the specimen described below has been tested and examined by BRANZ Ltd on behalf of

Ambitec (NZ) Limited
45 William Pickering Drive
Albany
New Zealand

- Test standard:** ISO 5660
- Specimen name:** Suave, Tierrafino, and Bone China polished surfaces
- Specimen description:** Polished surface on a standard grade paper faced plasterboard substrate
- Orientation:** Front face has a polished glossy finish and is lightly textured. Specimen coats the front face of standard grade paper faced plasterboard substrate.

A full description of the test specimen and the test results are given in BRANZ Test Report:

Fire Test FH 5385 – Test date 23rd and 25th October 2013

Regulatory authorities are advised to examine test reports before approving any product.

The test results were the basis for the following:

Building Code Document	Group Number Classification
NZBC Verification Method C/VM2 Appendix A	1-S

The average specific extinction area was less than the 250 m²/kg limit.



This Laboratory is accredited by International Accreditation New Zealand (IANZ). The tests reported herein have been performed in accordance with the laboratory's scope of accreditation.



REPORT NUMBER:

FH 5385

ISSUE DATE:

29 October 2013

EXPIRY DATE:

29 October 2018

PAGE:

12 of 12



THIS REPORT IS ONLY VALID WHEN A TYPE TEST SUMMARY APPEARS ON THE BRANZ LTD WEBSITE WWW.BRANZ.CO.NZ.
EXTRACTS OR ABRIDGEMENTS OF THIS REPORT SHALL NOT BE PUBLISHED WITHOUT PERMISSION FROM BRANZ LTD.