

BRANZ Type Test Summary

This is to certify that the specimen described below has been tested and examined by BRANZ Ltd on behalf of

Ambitec (NZ) Limited
45 William Pickering Drive
Albany
New Zealand

Test standard: ISO 5660
Specimen name: Suave and Tierrafino polished surfaces
Specimen description: Polished surface on 12 mm MDF substrate

Orientation: Front face has a polished glossy finish and is lightly textured.
Specimen coats the front face of an 12 mm MDF substrate

A full description of the test specimen and the test results are given in BRANZ Test Report:

Fire Test FH 5392 – Test date 23rd and 25th October 2013

Regulatory authorities are advised to examine test reports before approving any product.

The test results were the basis for the following:

Building Code Document	Group Number Classification
NZBC Verification Method C/VM2 Appendix A	3



This Laboratory is accredited by International Accreditation New Zealand (IANZ). The tests reported herein have been performed in accordance with the laboratory's scope of accreditation.



PROJECT NUMBER:
FT 5392

ISSUE DATE:
29 October 2013

EXPIRY DATE:
29 October 2018

PAGE:
12 of 12

MNV

PMW