

BRANZ Type Test Summary

This is to certify that the specimen described below has been tested and examined by BRANZ Ltd on behalf of

Ambitec (NZ) Limited
45 William Pickering Drive
Albany
New Zealand

Test standard: ISO 5660

Specimen name: Suave, Tierrafino, and Bone China polished surfaces

Specimen description: Polished surface on a standard grade paper faced plasterboard substrate

Orientation: Front face has a polished glossy finish and is lightly textured. Specimen coats the front face of standard grade paper faced plasterboard substrate.

A full description of the test specimen and the test results are given in BRANZ Test Report:

Fire Test FH 5385 – issued 3 September 2019

Regulatory authorities are advised to examine test reports before approving any product.

The test results were the basis for the following:

Building Code Document	Group Number Classification
NZBC Verification Method C/VM2 Appendix A	1-S



IANZ
ACCREDITED LABORATORY

This Laboratory is accredited by International Accreditation New Zealand (IANZ). The tests reported herein have been performed in accordance with the laboratory's scope of accreditation.



REPORT NUMBER:

FH 5385

ISSUE DATE:

3 September 2019

EXPIRY DATE:

3 September 2024

PAGE:

13 of 13

LFH

PCRC

THIS REPORT IS ONLY VALID WHEN A TYPE TEST SUMMARY APPEARS ON THE BRANZ LTD WEBSITE WWW.BRANZ.CO.NZ.
EXTRACTS OR ABRIDGEMENTS OF THIS REPORT SHALL NOT BE PUBLISHED WITHOUT PERMISSION FROM BRANZ LTD.