

# BRANZ Type Test Summary

This is to certify that the specimen described below has been tested and examined by BRANZ Ltd on behalf of

Ambitec (NZ) Limited  
45 William Pickering Drive  
Albany  
New Zealand

- Test standard:** ISO 5660
- Specimen name:** Suave, Tierrafino, and Bone China polished surfaces
- Specimen description:** Polished surface on 12 mm MDF substrate. Front face has a polished glossy finish and is lightly textured.
- Orientation:** Specimen coats the front face of a 12 mm MDF substrate

**A full description of the test specimen and the test results are given in BRANZ Test Report:**

Fire Test FH 5392 – issued 3 September 2019

**Regulatory authorities are advised to examine test reports before approving any product.**

**The test results were the basis for the following:**

Building Code Document	Group Number Classification
NZBC Verification Method C/VM2 Appendix A	3



This Laboratory is accredited by International Accreditation New Zealand (IANZ). The tests reported herein have been performed in accordance with the laboratory's scope of accreditation.



PROJECT NUMBER:

**FT 5392-2**

ISSUE DATE:

**3 September 2019**

EXPIRY DATE:

**3 September 2024**

PAGE:

**13 of 13**

LFH

PCRC